

Fire test certificates

Moulded skin doors

Core	Design	Edge	Thickness	Size	Result	Institute	Assesment
38 PV	single leaf	square	44 mm	820 x 1980	34 min	WARRES	max. dimension door frame / dimension
38 PV	single leaf	square	44 mm	824 x 1985	33 min	WARRES	
38 PV	single leaf glazed	square	44 mm	837 x 1981	32 min	WARRES	
38 PV	double leaf	square	44 mm	762 x 1981	31 min	WARRES	
48 PSF	single leaf	square	54 mm	839 x 1981	60 min	WARRES	